



HOUSING AUTHORITY OF THE CITY OF BRIDGEPORT,
D/B/A PARK CITY COMMUNITIES
150 HIGHLAND AVENUE
BRIDGEPORT, CT 06604

ADDENDUM # 2 – July 22, 2021

P.T. Barnum Bldg. 8 Fire Restoration

Solicitation Number: 180-MD-21-S

Solicitation Date: June 21, 2021

1. The following changes to the above-cited solicitation are hereby made:

The date for receipt of bids is hereby extended to Thursday, July 29, 2021, at 2:30 p.m.

2. Questions asked via e-mail bids@parkcitycommunities.org:

Response to Q3:

A3: Yes, Aluminum Windows must have a Wind Borne Debris Resistance rating, capable of resisting impact from windborne debris based on testing glazed windows identical to those specified, according to ASTM E 1886 and testing information in ASTM E 1996 and requirements of authorities having jurisdiction.

Changes to the Specifications

- Specification Section 085113 “Aluminum Windows”, Paragraph 2.1/A: Revise to indicate the following:
 - A. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
 1. Graham Architectural Products Corporation; Hurricane Resistant – HI2200 Series Double Hung (Basis-of-Design product).
 2. Kawneer North America; an Alcoa company; Hurricane Resistant double hung window product equal in performance to Graham Architectural Products Corporation; Hurricane Resistant – HI2200 Series Double Hung.
 3. TRACO; Hurricane Resistant double hung window product equal in performance to Graham Architectural Products Corporation; Hurricane Resistant – HI2200 Series Double Hung.
 4. Substitutions: Under provisions of Section 012500 “Substitution Procedures”.
- Specification Section 012300 “Alternates”, paragraph 3.1: Revise to indicate the following:

ADD ALTERNATE NO. 8: Harvey Building Products “Vigilance Impact-Rated Vinyl Windows”, or Approved Equals by Jeld-Wen and Pella: Add to the Base Bid the provision and installation of **Harvey Building Products “Vigilance” Impact-Rated Vinyl Windows, or Approved Equals by Jeld-Wen and Pella**, as indicated on the Drawings and in the Project Manual.

- Revision to the Bid Documents: In each apartment unit, Contractor to provide and install Appliances, as indicated below and as indicated on Drawings:
 - GE Hotpoint 30-inch Freestanding Gas Range, White, Model No. RGBS100DMWW.
 - Frigidaire 18-cubic feet top mount Refrigerator, White, Optional Icemaker, Model No. FFTR1814TW.

3. Except as provided herein, the terms and conditions of the original solicitation shall remain unchanged and in full force and effect.

END OF ADDENDUM #2

Please sign this addendum and acknowledge receipt on the acknowledgement of addenda form to be returned with your proposal.

Signature:
(Authorized Signature)

Typed Name and Title

Name of Firm

Date

Date Issued: July 22, 2021